

September 26, 2005

TOPP INDUSTRIES, INC.
KEVIN BIRCHMEIER
425 N STATE RD.25
PO BOX 420
ROCHESTER IN 46975

Re: Description: SEWAGE TANKS, FIBERGLASS
Manufacturer: TOPP INDUSTRIES, INC.
Product Name: PUMP TANK
Model Number(s): FB30X60F TANK WITH C30WF COVER, FFPWF COVER GASKET, PF200T PIPE
FLANGE AND U400 PIPE SEALS
Product File No: 20050689

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2011.

This approval supersedes the approval issued on January 4, 2001, under product file number 20002103.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002103.

This approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product as being equivalent to larger sized dose tanks that have a one-day reserve capacity located in the tank. The product meets the intent of approved component manuals that require that the tank have a one-day reserve capacity for the dose tank. The intent of the manuals is met since the installation of this product provides a method of providing a one-day reserve capacity in another tank located upstream of this tank.
- This product must be installed in conjunction with a time dose trash trap serving an ATU prior to the wastewater being discharged into this product. The installation must include a float in this product that is capable of monitoring the liquid level and shut off the power to the pump in the trash trap before the wastewater level comes within a distance of three inches of the inlet to this product.
- The dosing capacity of this product must meet the requirements of the system for which it serves.
- A permanent warning label that conforms to s. Comm 84.25 (8), Wis. Adm. Code, must be attached to the cover of this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov